

2.4.2015

DECLARATION OF CONFORMITY

This declaration certifies that the below mentioned apparatus confirms with the requirements of the following directives:

- EMC directive 2004/108/EC.
- Low voltage directive 2006/95/EC.

Apparatus:

- FIRESCAPE firealarm system.
 - FIRESCAPE control panel.
 - FS-UP user panel.
 - FS-HOAN, interface board for Hochiki addressable devices.
 - HOCHIKI ESP analog adressable devices.
 - HOCHIKI CDX-range conventional devices.

Manufacturer:

Oy Hedengren Ab
Security
Lauttasaarentie 50
P.O Box 110
FIN-00201 Helsinki

Standards wich are used as basis for conformity:

- EN54-2:1997 / AC:1999+A1:2006.
- EN54-4:1997 / AC:1999+A1:2002+A2:2006.
- EN 61000-6-3:2007/A1:2011
- SS3654:1998.
- SS3654 T1:2000 Amendment.

With substandards:

- EN 55022, CISPR 16-2-3.
- EN 55022, CISPR 16-2-1.
- IEC 61000-3-2.
- IEC 61000-3-3.
- IEC 1000-4-2:2001, 6kV contact, 8kV air.
- IEC 1000-4-3:2001, 10V/m.
- IEC 1000-4-4:2004, Mains 2kV / signal 1kV.
- IEC 1000-4-5:2006, Mains 2kV, Signal lines 1kV.
- IEC 1000-4-6:2007.
- IEC 1000-4-11:2004.

2.4.2015

The testing has been performed by the following companies:

- Nemko AS, Norway, report no. 249307: TRF EN 54-2, TRF EN 54-4, TRF SS3654.
- Nemko Oy

Oy Hedengren Security Ab


Kauko Pirskanen
Managing Director

