

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0470 - CPR - 0038

In compliance with Regulation 305/2011/EU of the European Parliament and the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to construction products

Fire Alarms - Control and Indicating Equipment

Product	Brand	Type
Fire alarm control panel	FIRESCAPE	FIRESCAPE
Addressable loop card	FIRESCAPE	FS-HOAN FS-LOOP-CARD-ADAPTER
Cabinet	FIRESCAPE	FS-MAP-CABINET FS-MAP-CABINET-DOOR FS-DOOR FS-BATTERY-CABINET FS-STACK-KIT
User panel	FIRESCAPE	FS-UP/xx (xx=country code)
Isolating transformer	Tufvassons	PVS-151/33

produced by :

Oy Hedengren Security AB
Lauttasaarentie 50
FI-00200 Helsinki, Finland

and produced in the factory of:

Stera Technologies Oy
Tierankatu 5,
FI-20520 Turku, Finland

This certificate attest that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 54-2:1997/AC:1999/A1:12006
EN 54-4:1997/AC:1999/A1:2002/A2:2006

under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 13. February 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the factory are not modified significantly.

Oslo, 13.02.2015

Notified Body Id. no. 0470
Nemko AS
P.O. Box 73 Blindern
NO-0314 OSLO, NORWAY



Roger Berget
Nemko AS