

## Hedsam X Version 15.2.2. Patch Update

An error has been found in the Hedsam X Databus Controller program, where the registrations are stored in the database with an incorrect date. This bug affects versions 15.1.0 through 15.2.1. This can be seen, for example, in the fact that the registrations do not accumulate the balance correctly.

There is a fix for the problem and you can download it from the Hedengren Security media bank:

<https://mediabank.hedengren.com>

### Instructions

1. Back up your current data.
2. Install the new Hedsam X Databus Controller 15.2.2.
3. Correct the incorrectly saved registrations with the *RegistCopy\_1996\_2024.bat* tool. The tool searches for registrations for October, November and December 1996. The registrations found will be copied to the corresponding dates in 2024.



**Note!** Do not run the program more than once, or the registrations may be copied multiple times.

During the run, the program first searches and lists the registrations it finds for the months to be copied. After that, it saves the registrations on the correct dates while again listing the registrations to be saved.