

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

0470 - CPR - 0038

In compliance with Regulation 305/2011/EU of the European Parliament and the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to construction products

## Fire Alarms - Control and Indicating Equipment

Product	Brand	Type
Fire alarm control panel	FIRESCAPE	FIRESCAPE
Addressable loop card	FIRESCAPE	FS-HOAN FS-LOOP-CARD-ADAPTER
Cabinet	FIRESCAPE	FS-MAP-CABINET FS-MAP-CABINET-DOOR FS-DOOR FS-BATTERY-CABINET FS-STACK-KIT
User panel	FIRESCAPE	FS-UP/xx (xx=country code)
Isolating transformer	Tufvassons	PVS-151/33

produced by :

**Oy Hedengren Security AB**  
**Lauttasaarentie 50**  
**FI-00200 Helsinki, Finland**

and produced in the factory of:

**Stera Technologies Oy**  
**Tierankatu 5,**  
**FI-20520 Turku, Finland**

This certificate attest that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 54-2:1997/AC:1999/A1:12006**  
**EN 54-4:1997/AC:1999/A1:2002/A2:2006**

under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 13. February 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the factory are not modified significantly.

Oslo, 13.02.2015

Notified Body Id. no. 0470  
 Nemko AS  
 P.O. Box 73 Blindern  
 NO-0314 OSLO, NORWAY



Roger Berget  
 Nemko AS