

## DECLARATION OF PERFORMANCE

### According to Construction Products Regulation EU N° 305/2011 N° 0832-CPD-1849

Product Name: ACC-E, ACC-E(WHT) and ACC-E(HFP)

Intended use: Intelligent addressable multi-criteria photoelectric smoke and heat point detector for use in fire detection and alarm systems for buildings

Manufactured by: Hochiki Corporation, Ejiri, Kakuda-shi, Miyagi 981-15, Japan

Authorised representative: Hochiki Europe (UK) Ltd, Grosvenor Road, Gillingham, Kent, ME8 0SA

System of Assessment: System 1

Assessed by: BRE Global Limited (Notified Body 0832) has performed type testing of the product, initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and evaluation of factory production control under system 1 and issued following certificate of conformity:

#### 0832 – CPD – 1849

Declared performance: All requirements including all essential characteristics<sup>(1)</sup> and corresponding performances<sup>(2)</sup> as described in the harmonised standards:  
EN54-5:2000 Fire detection and fire alarm systems - Part 5:  
Heat Detectors  
EN54-7:2000 Fire detection and fire alarm systems - Part 7:  
Smoke Detectors  
for the intended uses indicated above have been determined.

<sup>(1)</sup>See Annex A for the Essential Characteristics details

<sup>(2)</sup>See Annex B for additional performance details

The performance of the above mentioned products are in conformity with the performance and essential characteristics declared within this certificate. This declaration of performance is issued under the sole responsibility of Hochiki Corporation.

Signed for and on behalf of the manufacturer by:

.....  
Ray Turner  
Compliance Manager

Date of issue 27<sup>th</sup> June 2013

#### HOCHIKI EUROPE (UK) LIMITED

Grosvenor Road, Gillingham Business Park,  
Gillingham, Kent, ME8 0SA, United Kingdom  
Telephone: +44 (0)1634 260133  
Facsimile: +44 (0)1634 260132  
e-mail (UK Sales): sales@hochikieurope.com  
e-mail (Non UK Sales): export@hochikieurope.com  
www.hochikieurope.com

Reg. Address: 11 Raven Wharf, Lafone Street,  
Butlers Wharf, London SE1 2LR  
Registered in England no. 2639909  
VAT no. GB 573 8188 03

## Annex A - Essential Characteristics

Essential characteristics	EN54-5:2000 +A1:2002	EN54-7:2000 +A1:2002 +A2:2006	Performance
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions	4.2, 4.3, 5.2 to 5.6, 5.8	4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18	Pass
Operational reliability	4.4 to 4.11	4.2 to 4.7, 4.9 to 4.11	Pass
Tolerance to supply voltage	5.7	5.5	Pass
Durability of operational reliability and response delay; temperature resistance	5.9, 5.10	5.8, 5.9	Pass
Durability of operational reliability: humidity resistance	5.11, 5.12	5.10, 5.11	Pass
Durability of operational reliability: corrosion resistance	5.13	5.12	Pass
Durability of operational reliability: vibration resistance	5.14 to 5.17	5.13 to 5.16	Pass
Durability of operational reliability: electrical stability	5.18	5.17	Pass

## Annex B – Additional Performance Details

Mode 0 – Thermally enhanced smoke detector at 2% to 4.5%

Mode 1 – Optical smoke detector at 2% to 4.5%

Mode 2 – Fixed temperature heat detector at class A1 &amp; C

**HOCHIKI EUROPE (UK) LIMITED**

Grosvenor Road, Gillingham Business Park,  
 Gillingham, Kent, ME8 0SA, United Kingdom  
 Telephone: +44 (0)1634 260133  
 Facsimile: +44 (0)1634 260132  
 e-mail (UK Sales): sales@hochikieurope.com  
 e-mail (Non UK Sales): export@hochikieurope.com  
 www.hochikieurope.com

Reg. Address: 11 Raven Wharf, Lafone Street,  
 Butlers Wharf, London SE1 2LR  
 Registered in England no. 2639909  
 VAT no. GB 573 8188 03